

# NFRC Product Certification Authorization Report



**Manufacturer:** Coastal Industries, Inc.      **Product Series:** CII-S-3720 Single Slider      **Simulation Lab:** SEEL      **Initial Cert. Date:** 11/18/2015  
**Street:** 77 Newark Street      **Product Type:** HSOX      **Sim. Report #:** CII23101332-cR      **Re-Certification Date:** 06/06/2023  
**City/State/Zip:** Haverhill, MA 01832      **Air Leakage:**      **Sim. Report Date:** 02/22/2023      **Revised Date:** 03/03/2023  
**Print Date:** 10/04/2023      **Test Date:** 03/25/2022      **Expiration Date:** 03/25/2027

CPD Number: COA-M-21

IA: National Accreditation And Management Institute

Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00005-00001	7036-arg95-GCI  dl	VY/VY	2	0.036(2)	0.646	P2-S	Fill 1: ARG(95/5)	N		CL	0.28	0.30	0.54	62
	00005-00002	7036-arg95-GCI  dl  Rectangular	VY/VY	2	0.036(2)	0.646	P2-S	Fill 1: ARG(95/5)	G	0.75	CL	0.28	0.27	0.48	62
	00005-00003	7036-arg95-GCI  dl  SDL	VY/VY	2	0.036(2)	0.646	P2-S	Fill 1: ARG(95/5)	S	0.75	CL	0.28	0.27	0.48	62
	00006-00001	CG70-arg95-GCI  dl	VY/VY	2	0.025(2)	0.646	P2-S	Fill 1: ARG(95/5)	N		CL	0.28	0.27	0.53	62
	00006-00002	CG70-arg95-GCI  dl  Rectangular	VY/VY	2	0.025(2)	0.646	P2-S	Fill 1: ARG(95/5)	G	0.75	CL	0.28	0.24	0.47	62
	00006-00003	CG70-arg95-GCI  dl  SDL	VY/VY	2	0.025(2)	0.646	P2-S	Fill 1: ARG(95/5)	S	0.75	CL	0.28	0.24	0.47	62
	00007-00001	CG70-arg95-CG70-arg95-CG70  dl  Lower Saetting Block	VY/VY	3	0.025(2), 0.025(4), 0.025(5)	0.271,0.271	P2-S	Fill 1: ARG(95/5) , Fill 2: ARG(95/5)	N		CL	0.22	0.20	0.34	69
	00008-00001	CG70-arg95-CG70-arg95-CG70  dl  Lower Saetting Block  Rectangular	VY/VY	3	0.025(2), 0.025(4), 0.025(5)	0.271,0.271	P2-S	Fill 1: ARG(95/5) , Fill 2: ARG(95/5)	G	0.75	CL	0.23	0.18	0.30	69
	00009-00001	CG70-arg95-CG70-arg95-CG70  dl  Lower Saetting Block  SDL	VY/VY	3	0.025(2), 0.025(4), 0.025(5)	0.271,0.271	P2-S	Fill 1: ARG(95/5) , Fill 2: ARG(95/5)	S	0.75	CL	0.23	0.18	0.30	69

---

**Baseline Information**

<b>Test Lab</b>	<b>Test Date</b>	<b>Test Size</b>	<b>Tested U-Value</b>	<b>Standard U-Value</b>	<b>Test Report Number</b>
<b>TAIR</b>	<b>03/25/2022</b>	1500 mm x 1200 mm	0.260	0.260	NV-03669-D

**Comments:** CII23101332-c-A1 added options 7 - 9 on 10/04/2023.

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA  
Signature: \_\_\_\_\_

